

37U — TU G05 SERIES VALVE BOX & LID

Revised 02/2025 (Current revisions for the noted Standards apply)

STANDARDS:	Produced in accordance with and meeting applicable terms and provisions of ASTM A-48. All Tyler Union valve boxes when properly installed are suitable for use in conjunction with projects utilizing American Association of State and Highway Transportation Officials (AASHTO) standards. AASHTO compliance with H20 and H40 traffic loading.
INSTALLATION:	Per AWWA M44, Manual of Water Supply Practices.
COATING:	The asphaltic bituminous coating is applied to a minimum of 1.5 mil and the coating once dry is neither brittle when cold or sticky when exposed to the sun.
FEATURES:	<ul style="list-style-type: none"> • Lid provided with longer tynees to prevent movement. • Lids are available with "WATER", "SEWER" or blank marking. • Specialty marking available in domestic only; contact Tyler Union for more details. Available in an assembly, or pieces sold individually. • Straight body allows for easy assembly on AWWA C900 PVC Pipe. • Valve Box ribs provided to prevent movement. • No pre-cast required. • Import Box provided drilled and tapped for 1/4"-20 screw (screw not provided) • Domestic boxes can be drilled and tapped 1/4"-20 upon request. (screw not provided)
COATING:	Asphaltic or Primer per ANSI/AWWA C104/A21.4. Standard primer is Tnemec Pota Pox N140-1211. Contact Tyler Union for additional coating options.
WEIGHTS:	<ul style="list-style-type: none"> • Body: 42lbs. • Lid: 16lbs.

